



LEGEND	
MARKER (DETAIL "A")	□
FIRE HYDRANT	⊗

MARKERS - SHALL BE BLUE 2-WAY ITL INDUSTRIES RAY-D-LITE #28 OR EQUAL.
 ADHESIVE - AN AMPLIFIED AMOUNT OF TWO PART (A & B) EPOXY OR EQUAL.
 SURFACES- CLEAN AND DRY PRIOR TO INSTALLATION PER MANUFACTURER'S RECOMMENDATIONS. INSTALL MARKERS WITH REFLECTIVE SURFACES FACING ONCOMING VEHICLES AND OFFSET 2" FROM LANE LINES.

NOTES:

1. FIRE HYDRANTS SHALL BE LOCATED 6'-0" FROM FACE OF CURB TO CENTER OF HYDRANT OR 2'-0" FOR SIDEWALKS WIDER THAN 5' IN WIDTH. STATE LAW REQUIRES A 4' MINIMUM CLEAR SIDEWALK AREA.
2. FIRE DEPARTMENT WILL PROVIDE LOCATION(S) FOR ALL MARKERS IN PRIVATE RESIDENTIAL DEVELOPMENTS, COMMERCIAL LOTS, AND ALL OTHER AREAS OUTSIDE OF PUBLIC RIGHT OF WAY.
3. MARKERS MUST BE INSTALLED AT ALL NEW AND RELOCATED FIRE HYDRANTS AND WITHIN ALL RESURFACING PROJECTS.
4. FOR STREETS WITHOUT LANE LINES OR STREETS WITH RAISED PAVEMENT MARKERS AND NO PAINTED LANE LINES, INSTALL MARKERS ON CENTERLINE OR IN LINE WITH EXISTING MARKERS.

CITY OF NEWPORT BEACH PUBLIC WORKS DEPARTMENT	APPROVED:	
	DIRECTOR OF PUBLIC WORKS R.C.E. NO. 12806	
FIRE HYDRANT MARKERS	DATE	23 Sep 1993
	DRAWN	M. GRACIA
		SCALE N.T.S.
		STD-902-L