






Zone	Construction Requirements
A 	No special requirements.
B 	The water main shall be Class 52 DIP or Class 200 PVC pipe (SDR-14).
C 	The water main shall be Class 52 DIP or Class 200 PVC pipe (SDR-14). There shall be no joints in this zone.
R 	Restricted, no water mains will be allowed without written State Health Department approval.
P 	Prohibited, no water mains are to be constructed in this zone.

GENERAL NOTES:

1. This drawing does not indicate construction requirements when existing sewer is a force main. Consult Utilities Department on State Health Department regulations.
2. This drawing assumes that no special construction methods have been used for sewer installation.

CITY OF NEWPORT BEACH
PUBLIC WORKS DEPARTMENT

**WATER & SEWER MAIN
SEPARATION REQUIREMENTS**

APPROVED:



RCE NO. 36106

PUBLIC WORKS DIRECTOR

Drawn: M. Elias

Scale: N.T.S.

Date: Jan. 2004

F:\USERS\PBW\Shared\CAD STD\STD Details\2003 - Std\STD-Water

DRAWING NO.

STD-533-L