



### CONSTRUCTION NOTES:

- ① 8" diameter schedule 40 P.V.C. pipe.
- ② Cast iron frames and covers shall be triangular, Brooks Products No. 4TT, J&R No. 4T, or Eisel Enterprises 1-4, marked "water".
- ③ The valve box should not be (load) weight bearing on the valve riser.
- ④ The tracing wire shall be attached outside the valve riser and 18" of wire shall drop into the riser from the valve box.

### GENERAL NOTES:

1. Concrete shall be 560-C-3250.
2. Portions of this standard also apply to sewer cleanouts.

CITY OF NEWPORT BEACH  
PUBLIC WORKS DEPARTMENT

## VALVE BOX COVER AND RISER

APPROVED:

PUBLIC WORKS DIRECTOR

RCE NO. 36106

Drawn: M. Elias

Scale: N.T.S.

Date: Jan. 2004

F:\USERS\PBW\Shared\CAD STD\STD Details\2003 - Std\STD Water

DRAWING NO.

STD-511-L