



**CONSTRUCTION NOTES**

**\* ALL SERVICES SHALL BE ORIENTED SHOWN ABOVE**

- ① REMORTAR TO THE BOTTOM OF THE CORPORATION STOP.
- ② INSTALL HEAVY BLACK STEEL "THREAD-O-LET" WELD COUPLING. FOR 1" SERVICE, USE 1 1/2" (THREAD-O-LET) WELD COUPLING. FOR A 2" SERVICE, USE A 2 1/2" (THREAD-O-LET) WELD COUPLING.
- ③ INSTALL TYPE 316 STAINLESS STEEL BUSHING. ONE SIZE LARGER THAN THE SERVICE.
- ④ INSTALL CORPORATION STOP WITH IRON PIPE THREAD INLET AND COPPER FLARE TUBE NUT OUTLET FOR 1" (SEE STD 502) OR IRON PIPE THREAD OUTLET FOR 2" (SEE STD 503).

**GENERAL NOTES**

- 1. ALL CONNECTIONS TO LINED AND COATED STEEL MAINS REQUIRE APPROVAL FROM THE UTILITIES DEPARTMENT.
- 2. ALL LINING AND COATING DAMAGED OR REMOVED FOR INSTALLATION OF THE SERVICE SHALL BE REPLACED TO ITS ORIGINAL OR NEW CONDITION, WHICHEVER IS SUPERIOR.

FORMER CITY STANDARD PLAN NUMBER (2004 EDITION): STD 505-L

APP. <i>James M. Hinkle</i>	51568	11/24/2020			
CITY ENGINEER	RCE	DATE	NO.	DATE	DESCRIPTION OF REVISIONS

**CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS**

DRAWN: M. ELIAS	<b>SERVICE TAP TO LINED AND COATED STEEL MAINS</b>	STANDARD DRAWING NO.
DATE: 11/3/2020		<b>510</b>
		SHEET 1 OF 1