



NOTE:

2" GALVANIZED IRON PIPE MONUMENTS SHALL BE SET AT EACH BOUNDARY CORNER OF A SUBDIVISION, ALONG EXTERIOR BOUNDARIES AT INTERVALS NOT OVER 500 FEET, AT THE BEGINNING AND END OF EXTERIOR PROPERTY LINE CURVES. 1" GALVANIZED IRON PIPE MONUMENTS SHALL BE SET AT INTERIOR LOT/PARCEL CORNERS AND PROPERTY LINE CURVES.

DESCRIPTION	MINIMUM SIZE	MINIMUM LENGTH	RELATIONSHIP TO SURFACE
GALVANIZED IRON PIPE WITH 5/8" LONG BRASS NAIL AND 3/4" DIA. BRASS TAG.	2"-EXT. BDY. 1"-INT. BDY.	36" 24"	PIPE SHALL BE FLUSH NAIL AND TAG AND BE RECESSED 1/4" MIN. BELOW TOP OF IRON PIPE
GALVANIZED SPIKE WITH 3/4" GALVANIZED WASHER AND 1-1/2" BRASS TAG.	3/8" SPIKE	4"	TOP OF SPIKE TO BE FLUSH OR RECESSED SLIGHTLY BELOW TOP OF FINISHED SURFACE
LEAD WITH 5/8" LONG BRASS NAIL AND 3/4" DIA. BRASS TAG			NAIL AND TAG SHALL BE RECESSED 1/4" BELOW TOP OF EXISTING SURFACE
3/4" DIA. BRASS TAG IN EPOXY			TAG SHALL BE RECESSED 1/4" BELOW TOP OF EXIST. SURFACE

REV. 7/2002 MW
REV. 9/93

CITY OF NEWPORT BEACH
PUBLIC WORKS DEPARTMENT

APPROVED:

RCE NO. 36106

PUBLIC WORKS DIRECTOR

Date: JULY, 1994

Scale: N.T.S.

Drawn by: M.GRACIA

F:\USERS\PBW\Shared\CAD_STD\STD Details\2003_Std

**SUBDIVISION AND LOT
CORNER MONUMENTS**

DRAWING NO.

STD-117-L