



NOT TO SCALE

**GENERAL NOTES**

1. METER BOXES SHALL BE PLACED SUCH THAT SPACE BETWEEN BOXES IS A MINIMUM OF 4 INCHES.
2. WHERE PRACTICAL, A CONCRETE SLAB SHALL BE POURED AROUND AND BETWEEN METER BOXES.
3. WATER SERVICE CONNECTIONS TO THE MAIN SHALL BE PER STD 502 OR STD 503.
4. CONCRETE METER BOX SHALL BE FROM THE FOLLOWING (NO APPROVED EQUAL):

FOR 1" METERS:  
1" DFW METER BOX W/ DFW486C-AF4T MUE NWPT LID

FOR 2" METERS:  
2" DFW METER BOX W/ DFW65CB-AF4T MUE NWPT LID

5. METER BOXES SUBJECT TO TRAFFIC LOADING SHALL HAVE TRAFFIC RATED LIDS.

FORMER CITY STANDARD PLAN NUMBER (2004 EDITION): STD 518-L

APP. <i>James M. Hinkle</i>	51568	11/24/2020			
CITY ENGINEER	RCE	DATE	NO.	DATE	DESCRIPTION OF REVISIONS

**CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS**

DRAWN: M. ELIAS	<b>MULTIPLE WATER METER &amp; SERVICE BOX INSTALLATIONS</b>	STANDARD DRAWING NO.
DATE: 11/3/2020		<b>505</b>
		SHEET 1 OF 1