


PLAN VIEW

CONSTRUCTION NOTES

- ① BRONZE DOUBLE STRAP SERVICE SADDLE, JONES J-979 OR FORD F202B WITH I.P. THREAD. FOR PVC, USE J-969 SERIES OR 202BS. STAINLESS STEEL SERVICE SADDLE SHALL BE WRAPPED IN 10 MIL THICK PLASTIC WRAP.
- ② 2" CORP STOP. MIP x MIP, JONES E-1943 OR FORD FB500-7.
- ③ 2" BRASS COUPLING, FIP x FIP, MADE IN USA.
- ④ 2" COPPER ADAPTOR, MALE NPT.
- ⑤ 2" COPPER TUBING, TYPE K.



SECTION A-A

GENERAL NOTES

- 1. REFER TO STANDARD DRAWING STD 503 FOR ADDITIONAL WATER SERVICE DETAILS.
- 2. THIS STANDARD DRAWING IS APPLICABLE TO 2" SERVICES ONLY.

FORMER CITY STANDARD PLAN NUMBER (2004 EDITION): STD 516-L

APP. *James M. Hinkle* 51568 11/24/2020
 CITY ENGINEER RCE DATE

NO.	DATE	DESCRIPTION OF REVISIONS

CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS

DRAWN: M. ELIAS
 DATE: 11/3/2020

MULTIPLE WATER SERVICE CONNECTION TO MAIN

STANDARD DRAWING NO.
504
 SHEET 1 OF 1