



H	t
UNDER 8'	8"
8'-1" & OVER	10"

NOTES:

1. REINFORCING STEEL SHALL BE STRAIGHT BARS 1 1/2" CLEAR FROM FACE OF CONCRETE.
2. P-DEPTH, P, MAY BE REDUCED TO AN ABSOLUTE LIMIT OF 6" WHEN LARGER VALUE OF P WOULD REDUCE H TO 3'-6" OR LESS.
3. STATIONS OF MANHOLES SHOWN ON PLAN APPLY AT CENTERLINE OF SHAFT. ELEVATIONS ARE SHOWN AT SHAFT CENTER AND REFER TO THE PROLONGED INVERT GRADE LINE.

FORMER CITY STANDARD PLAN NUMBER (2004 EDITION): STD 310-L

APP. *James M. Hinkle* 51568 11/24/2020
CITY ENGINEER RCE DATE

NO.	DATE	DESCRIPTION OF REVISIONS

CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS

DRAWN: M. ELIAS
DATE: 11/3/2020

JUNCTION STRUCTURE No. 1

STANDARD DRAWING NO.
311
SHEET 1 OF 1