

City of Newport Beach - Building Department

-

ELECTRICAL CODE POLICY

Effective Date	Subject	Policy No.
November 9, 1999	Electrical Metallic Tubing (EMT) In Exposed Exterior Locations	N.E.C 348.1

This policy amends the National Electrical Code Article 348.1 to prohibit the use of E.M.T. conduit in exposed exterior locations due to the local corrosive air conditions, which reduce the useable life of the product to an unacceptable level.

Jay Elbetta, Building Director