



NOTES:

1. CONCRETE SHALL BE 560-C-3250.
2. ALL HARDWARE SHALL BE STAINLESS STEEL (THREADED STOCK, WASHERS, LOCK WASHERS AND NUTS).
3. TO SUPPORT THE PIPE AND COLLAR, UNI-STRUTS SHALL BE EMBEDDED INTO THE SAND A MINIMUM OF 36-INCHES AND FASTENED TO A GALVANIZED CHAIN WRAPPED AROUND THE PIPE.

APP. <i>James M. Hinkle</i>	51568	11/24/2020			
CITY ENGINEER	RCE	DATE			
			NO.	DATE	DESCRIPTION OF REVISIONS

CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS

DRAWN: P. KHARAZMI	<h1>STORM DRAIN PIPE COLLAR</h1>	STANDARD DRAWING NO.
DATE: 11/3/2020		<h2>326</h2>
		SHEET 1 OF 1