


CONSTRUCTION NOTES

- ① INSTALL MJ x MJ x MJ TEE WITH RETAINER GLANDS.
- ② INSTALL PVC C-900 MOA PIECE.
- ③ ALL BONNET SCREWS AND CAP NUTS SHALL BE TYPE 316 STAINLESS STEEL.
- ④ THRUST BLOCK PER STD 516-A.

NOTE:
ALL DUCTILE IRON FITTINGS SHALL BE ENCASED IN POLYETHYLENE WRAP PER AWWA STANDARD C105.

APP. 	51568 RCE	11/24/2020 DATE	
CITY ENGINEER	RCE	DATE	

CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS

DRAWN: M. ELIAS	<h1 style="margin: 0;">FITTING DETAIL</h1>	STANDARD DRAWING NO. <h1 style="margin: 0;">515</h1> SHEET 1 OF 1
DATE: 11/3/2020		