



# CITY OF NEWPORT BEACH

## COMMUNITY DEVELOPMENT DEPARTMENT BUILDING DIVISION

100 Civic Center Drive | P.O. Box 1768 | Newport Beach, CA 92658-8915  
www.newportbeachca.gov | (949) 644-3200

### COMMERCIAL (NON-RESIDENTIAL)

### Electric Vehicle Charging Station (EVCS) Eligibility Checklist for Expedited Permitting

**JOB ADDRESS:** \_\_\_\_\_

The purpose of this checklist is to determine the eligibility for expedited EVCS permitting. All questions requiring code compliance must comply to qualify for expedited review.

TYPE OF CHARGING STATION(S)	POWER LEVELS (PROPOSED CIRCUIT RATING)	CHECK ONE
Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	
Level 2 – 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps	
Level 2 – 6.6 kW (medium)	208/240 VAC at 40 Amps	
Level 2 – 9.6 kW (high)	208/240 VAC at 50 Amps	
Level 2 – 19.2 kW (highest)	208/240 VAC at 100 Amps	
Other (provide detail)	Provide rating:	

PERMIT APPLICATION	YES	NO
A. Does the application include EVCS manufacturer's specs and installation guidelines?		
B. Is the building application complete with the following information: Project address, applicant/owner/contractor name, license #, and phone numbers, email address, etc?		

ELECTRIC LOAD CALCULATION WORKSHEET	YES	NO
C. Is an electrical load calculation worksheet included? (CEC 220)?		
D. Based on the load calculation worksheet, is a new electrical service panel upgrade required? 1) If yes, do plans include the electrical service panel upgrade?		
E. Is the charging circuit appropriately sized for a continuous load of 125% (CEC 210.20)?		
F. If charging equipment proposed is a Level 2 – 9.6 kW station with a circuit rating of 50 Amps or higher, is a completed circuit card with electrical calculations included with the single line diagram?		

SITE PLAN & SINGLE LINE DRAWING	YES	NO
G. Is a site plan and electrical plan with a single-line diagram included with the permit application? 1) If mechanical ventilation requirements are triggered for indoor venting requirements (CEC 625.52 (B)), is a mechanical plan included with the permit application?		
H. Is the site plan (min. 18" x 24") fully dimensioned and drawn to scale? 1) Showing location, size, and use of all structures 2) Showing location of electrical panel to charging system 3) Showing type of charging system and mounting		

COMPLIANCE WITH 2022 CALIFORNIA ELETRICAL CODE (TITLE 24, PART 3)	YES	NO
I. Does the plan include EVCS Manufacturer's specs and installation guidelines?		
J. Does the electrical plan identify the amperage and location of existing electrical service panel?		

<b>COMPLIANCE WITH 2022 CALIFORNIA ELETRICAL CODE (TITLE 24, PART 3)</b>	<b>YES</b>	<b>NO</b>
1) If yes, does the existing panel schedule show room for additional breakers?		
K. Is the charging unit rated more than 60 amps or more than 150V to ground?		
1) If yes, are disconnecting means provided in a readily accessible location in line of site and within 50' of EVCS? (CEC 625.43)??		
L. Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing Mark? (UL 2202/UL 2200)		
M. If trenching is required, is the trenching detail called out? Check "Yes" if no trenching.		
1) Is the trenching in compliance with electrical feeder requirements from structure to structure? (CEC 225)		
2) Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per CEC 300)		

<b>COMPLIANCE WITH 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE (TITLE 24, PART 11)</b>	<b>YES</b>	<b>NO</b>
N. Do the Cal Green EV Readiness installation requirements apply to this project?		
1) Do the plans demonstrate conformance with Cal Green Table 5.106.5.3.1?		
2) Do the EVCS accessible in accordance with California Building Code, Chapter 11B Section 11B-228.3?		

<b>COMPLIANCE WITH 2022 CALIFORNIA BUILDING CODE, CHAPTER 11B ACCESSIBILITY</b>	<b>YES</b>	<b>NO</b>
O. Do the plans clearly depict all required accessible EVCS features for the disabled?		
1) Do the plans identify the correct number and type of accessible EVCS stalls required in accordance with Table 11B-228.3.2.1?		
2) Do the plans detail compliance with the accessible EVCS features required by 11B-812 and Figure 11B-812.9?		

**I certify that the above information is true and correct.**

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Print Name: \_\_\_\_\_

Phone #: \_\_\_\_\_