

| <b>October, 2024</b>         | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | 2.0 ppt                               | 2.1 ppt                | ND                  | 3.7 ppt               | ND                 |
| PFHxS                        | 2.3 ppt                               | 4.11 ppt               | ND                  | 4.6 ppt               | ND                 |

| <b>July, 2024</b>            | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | 2.1 ppt                | ND                  | 4.5 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.8 ppt                | ND                  | 4.6 ppt               | ND                 |

| <b>April, 2024</b>           | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | ND                     | ND                  | 4.1 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.5 ppt                | ND                  | 4.8 ppt               | ND                 |

| <b>January, 2024</b>         | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | ND                     | ND                  | 4.7 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.3 ppt                | ND                  | 5.4 ppt               | ND                 |

| <b>October, 2023</b>         | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | ND                     | ND                  | 3.9 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.7 ppt                | ND                  | 4.6 ppt               | ND                 |

| <b>July, 2023</b>            | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | ND                     | ND                  | 3.9 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.1 ppt                | ND                  | 4.2 ppt               | ND                 |

| <b>April, 2023</b>           | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | ND                                    | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | ND                                    | ND                     | ND                  | 4.3 ppt               | ND                 |
| PFHxS                        | ND                                    | 3.0 ppt                | ND                  | 4.5 ppt               | ND                 |

| <b>January, 2023</b>         | <b>PFAS Quarterly Testing Results</b> |                        |                     |                       |                    |
|------------------------------|---------------------------------------|------------------------|---------------------|-----------------------|--------------------|
| <b>PFAS Compounds Tested</b> | <b>16th Street Reservoir</b>          | <b>Dolphin Shallow</b> | <b>Dolphin Deep</b> | <b>Tamura Shallow</b> | <b>Tamura Deep</b> |
| PFOA                         | Not Tested                            | ND                     | ND                  | ND                    | ND                 |
| PFOS                         | Not Tested                            | ND                     | ND                  | 3.5 ppt               | ND                 |
| PFHxS                        | Not Tested                            | 3.4 ppt                | ND                  | 4.0 ppt               | ND                 |