

July, 2024	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	2.1 ppt	ND	4.5 ppt	ND
PFHxS	ND	3.8 ppt	ND	4.6 ppt	ND

April, 2024	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	4.1 ppt	ND
PFHxS	ND	3.5 ppt	ND	4.8 ppt	ND

January, 2024	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	4.7 ppt	ND
PFHxS	ND	3.3 ppt	ND	5.4 ppt	ND

October, 2023	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	3.9 ppt	ND
PFHxS	ND	3.7 ppt	ND	4.6 ppt	ND

July, 2023	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	3.9 ppt	ND
PFHxS	ND	3.1 ppt	ND	4.2 ppt	ND

April, 2023	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	ND	ND	4.3 ppt	ND
PFHxS	ND	3.0 ppt	ND	4.5 ppt	ND

January, 2023	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	Not Tested	ND	ND	ND	ND
PFOS	Not Tested	ND	ND	3.5 ppt	ND
PFHxS	Not Tested	3.4 ppt	ND	4.0 ppt	ND