



CITY OF NEWPORT BEACH

COMMUNITY DEVELOPMENT DEPARTMENT BUILDING DIVISION

100 Civic Center Drive | P.O. Box 1768 | Newport Beach, CA 92658-8915
www.newportbeachca.gov | (949) 644-3200

2019 CAL GREEN ADDITIONS/ALTERATIONS - NONRESIDENTIAL MINIMUM REQUIREMENTS

2019 California Green Building Standards Code (CG) is applicable to building additions of 1,000 square feet or greater, and/or building alterations with a permit valuation of \$200,000 or above. (NBMC 15.11.010, CG Section 101.3.1)

DIVISION 5.3-WATER EFFICIENCY AND CONSERVATION

1. **Meters.** Separate submeters or metering devices shall be installed for the uses described in Section 5.303.1.1 and Section 5.303.1.2 (**5.303.1**)
 - A. **Additions to existing buildings in excess of 50,000 square feet.** Separate submeters shall be installed as follows (**5.303.1.1**):
 1. For each tenant consuming more than 100 gal/day.
 2. Where separate submeters for individual building tenants are unfeasible, for water supplied to the following subsystems:
 - a. Makeup water for cooling towers where flow through is greater than 500 gpm
 - b. Makeup water for evaporative coolers greater than 6 gpm
 - c. Steam and hot-water boilers with energy input more than 500,000 Btu/h
 - B. **Excess consumption.** Any tenant within an addition that is projected to consume more than 1,000 gal/day. (**5.303.1.2**).
2. New plumbing fixtures and fittings in additions or areas of alterations to the building shall comply with the following (**5.303.5**):

| FIXTURE TYPE | MAXIMUM FLOW RATE |
|-------------------------------------|--|
| Single Showerheads | 1.8 gpm @ 80 psi |
| Multiple Showerheads | Combine flow rate of 1.8 gpm @80 psi |
| Nonresidential Lavatory Faucets | 0.5 gpm @ 60 psi |
| Kitchen Faucets | 1.8 gpm @ 60 psi |
| Metering Faucets | 0.20 gallons per cycle maximum |
| Wash Fountains | 1.8 gal per minute/20{rim space (inches) @ 60 psi |
| Metering Faucets for Wash Fountains | 0.20 gal per minute/20{rim space (inches) @ 60 psi |
| Water Closets | 1.28 gallons/flush |
| Wall Mounted Urinal | 0.125 gallons/flush |
| All Other Types of Urinal | 0.5 gallons/flush |

3. Tank-type water closets and showerheads shall be certified to the performance criteria of the U.S. EPA WaterSense Specification (**5.303.3.1**).
4. Combined flow rate of all showerheads controlled by a single valve shall not exceed 1.8 gallons per minute at 80 psi. (**5.303.3.3.2**)
5. Food waste disposers shall either modulate the use of water to no more than 1 gpm when not is use or shall automatically shut off after no more than 10 minutes of inactivity. Disposers shall use no more than 8 gpm of water. (**5.303.4**)

6. Nonresidential developments shall comply with City's water efficient landscape ordinance or the current California Department of Water Resources' Model Water Efficient Landscape Ordinance (MWELO). **(5.304.1, NBMC 14.17)**

DIVISION 5.4- MATERIAL CONSERVATION AND RESOURCE EFFICIENCY

7. **Moisture control.** Employ moisture control measures by the following methods. **(5.407.2)**
 - A. Prevent irrigation spray on structures. **(5.407.2.1)**
 - B. Install flashings integrated with a drainage plane. **(5.407.2.2.2)**
8. Construction waste shall be collected using City Franchise Hauler. Recycle and/or salvage for reuse a minimum of 65 percent of the nonhazardous construction and demolition waste. **(5.408.1)**
9. Universal Waste items such as fluorescent lamps and ballast and mercury containing thermostats as well as other California prohibited Universal Waste materials are disposed of properly and are diverted from landfills shall be provided to building inspector prior to final. **(5.408.2)**
10. **Excavated soil and land clearing debris.** 100% of trees, stumps, rocks and associated vegetation and soils resulting land clearing shall be recycled **(5.408.3)**

Building Maintenance and Operation

11. **Testing and adjusting.** Testing and adjusting of new systems shall be required for new systems serving additions or alterations. **(5.410.4)**
 - A. **Systems.** Develop a written plan of procedures for testing and adjusting systems for the system listed in Section 5.410.4.2. **(5.410.4.2)**
 - B. **Procedures.** Perform testing and adjusting procedures in accordance with applicable standards on each system. **(5.410.4.3)**
 - C. **HVAC balancing.** Before a new space-conditioning system serving a building or space is operated for normal use, balance the system in accordance with the procedures defined by national standards listed in Section 5.410.4.3.1 or other method approved by Building Official. **(5.410.4.3.1)**
 - D. **Reporting.** After completion of testing, adjusting, and balancing, provide a final report of testing signed by the individual responsible for performing these services. **(5.410.4.4)**
 - E. **Operation and maintenance manual.** Provide the building owner or representative with detailed operating and maintenance instructions and copies of guaranties/warranties for each system prior to final inspection. **(5.410.4.5)**
 - F. **Inspections and reports.** Include a copy of all inspection verifications and reports required by the Building Official. **(5.410.4.5.1)**

DIVISION 5.5-ENVIRONMENTAL QUALITY

12. **Temporary ventilation.** If the HVAC system is used during the construction, use return air filters with a MERV of 8 based on ASHRAE 52.2-1992 or an average efficiency of 30% based on ASHRAE 52.1-1992. Replace all filters immediately prior to occupancy. **(5.504.1)**
13. **Covering of duct openings of mechanical equipment during construction.** At the time of rough installation and during storage on the construction site until final startup of the heating, cooling and ventilating equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheet metal or other methods acceptable to the enforcing agency to reduce the amount of dust, water and debris which may enter the system. **(5.504.3)**

14. Finish material pollutant control. (5.504.4)

- A. **Adhesives, sealants or caulks.** Adhesives and sealants used on the project shall meet the requirements of the following standards. **(5.504.4.1)**
 - 1. Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers and caulks shall comply with SCAQMD Rule 1168 VOC limits as shown in Tables 5.504.4.1 and 5.504.4.2.
 - 2. Aerosol adhesives and smaller unit size of adhesives and sealant or caulking compounds (which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards
 - B. **Paints and coatings.** Architectural paints and coatings shall comply with Table 5.504.4.3. **(5.504.4.3)**
 - 1. Aerosol paints and coatings shall meet the Product-Weighted MIR Limits for ROC in Section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances **(5.504.4.3.1)**
 - C. **Carpet systems.** All carpet installed in the building interior shall meet the testing and product requirements of one of the following standards **(5.504.4.4)**:
 - 1. Carpet and Rug Institute's Green Label Plus Program
 - 2. NSF/ANSI 140 at the Gold level or higher;
 - 3. Scientific Certifications Systems Sustainable Choice;
 - 4. Compliant with VOC emission limits and testing requirements specified in CDPH Standard Method V1.1 or Specification 01350; or
 - 5. Compliant with the Collaborative for High Performance Schools California (2014 CA-CHPS) Criteria and listed in the CHPS High Performance Product Database.
 - D. All carpet cushion installed in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program. **(5.504.4.4.1)**
 - E. All carpet adhesive shall meet the requirements of Table 5.504.4.1. **(5.504.4.4.2)**
 - F. **Composite wood products.** Hardwood plywood, particleboard and medium density fiberboard composite wood products used interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4. **(5.504.4.5)**
 - G. **Resilient flooring systems.** For 80 percent of floor area receiving resilient flooring, installed resilient flooring shall meet at least one of the following **(5.504.4.6)**:
 - 1. Certified under the Resilient Floor Covering Institute (RFCI) FloorScore program;
 - 2. Compliant with the VOC emission limits and testing requirements specified in the California Department of Public Health's 2010 Standard Method for Testing and Evaluation Chambers, Version 1.1, February 2010;
 - 3. Compliant with the Collaborative for High Performance Schools California (2014 CA-CHPS) Criteria and listed in the CHPS High Performance Product Database;
 - 4. Products certified under UL GREENGUARD Gold.
 - H. **Filters.** In mechanically ventilated buildings, provide regularly occupied area of the building with air filtration media for outside and return air that provides at least a MERV of 13. MERV 13 filters shall be installed prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual. **(5.504.5.3)**
15. **Carbon dioxide (CO₂) monitoring.** For buildings equipped with demand control ventilation, CO₂ sensors and ventilation controls shall be specified and installed in accordance with the requirements of the California Energy Code, CCR, Section 120(c)(4). **(5.506.2)**
16. Install HVAC, refrigeration, and fire suppression equipment that does not contain CFCs. **(5.508.1.1)**
17. Install HVAC, refrigeration, and fire suppression equipment that does not contain Halons. **(5.508.1.2)**

Installer and Special Inspector Qualifications

18. HVAC system installers shall be trained and certified or work under direct supervision of trained and certified installers in the proper installation of HVAC systems. **(702.1)**
19. HVAC special inspectors must be qualified and able to demonstrate competence in the discipline they are inspecting. **(702.2)**

DOCUMENTATIONS

20. A report of commission process activities undertaken through the design and construction phases of the building project shall be completed and provided to the owner or representative. **(5.410.2.6)**
21. An operation and maintenance manual, CD, web-based reference or other approved media shall be provided by the builder to the building occupant or owner at the final inspection. It shall include operation and maintenance instruction of the equipment and appliances. **(5.410.4.5)**
22. Documentations of compliance with VOC limits in architectural paintings and coatings as specified in the Table 5.504.4.3 shall be provided at the request of the Building Inspector. **(5.504.4.3.2)**
23. Documentations of compliance with formaldehyde limits as specified in the Table 5.504.4.5 shall be provided when requested by building official by one of the methods **(5.504.4.5.3)**
 - A. Product certification and specifications
 - B. Chain of custody certifications
 - C. Product, labeled and invoiced as meeting the Composite Wood Products regulation
 - D. Exterior grade products marked as meeting the PS-1 or PS-2 standards of the Engineered Wood Association, the Australian AS/NZS 2269 or European 636 3S standards
 - E. Other methods approved by the building official.
24. Documentations verifying that resilient flooring materials meet the pollutant emission limits shall be provided. **(5.504.4.6.1)**
25. Documentations of acoustical analysis demonstrating compliance with interior sound levels shall be prepared by personnel approved by the architect or engineer of record. **(5.507.4.2.2)**
26. Documentation which shows compliance with CAL Green Code including construction documents, plans, specifications, builder or installer certification, and inspection reports and verification shall be available at the final inspection. **(703.1)**
27. CAL Green Documentation Compliance Certification form (City form) is required to be submitted to the Building Inspector prior to final building inspection. **(Section 703.1)**

2019 CALIFORNIA GREEN BUILDING STANDARDS CODE

VOC & FORMALDEHYDE LIMITS

| TABLE 5.504.4.3 VOC CONTENT LIMITS FOR ARCHITECTURAL COATINGS ^{2,3} (Grams of VOC per Liter of Coating, Less Water and Less Exempt Compounds) | |
|---|------------------|
| COATING CATEGORY | VOC LIMIT |
| Flat coatings | 50 |
| Nonflat coatings | 100 |
| Nonflat-high gloss coatings | 150 |
| Specialty Coatings | |
| Aluminum roof coatings | 400 |
| Basement specialty coatings | 400 |
| Bituminous roof coatings | 50 |
| Bituminous roof primers | 350 |
| Bond breakers | 350 |
| Concrete curing compounds | 350 |
| Concrete/masonry sealers | 100 |
| Driveway sealers | 50 |
| Dry fog coatings | 150 |
| Faux finishing coatings | 350 |
| Fire resistive coatings | 350 |
| Floor coatings | 100 |
| Form-release compounds | 250 |
| Graphic arts coatings (sign paints) | 500 |
| High temperature coatings | 420 |
| Industrial maintenance coatings | 250 |
| Low solids coatings ¹ | 120 |
| Magnesite cement coatings | 450 |
| Mastic texture coatings | 100 |
| Metallic pigmented coatings | 500 |
| Multicolor coatings | 250 |
| Pretreatment wash primers | 420 |
| Primers, sealers, and undercoaters | 100 |
| Reactive penetrating sealers | 350 |
| Recycled coatings | 250 |
| Roof coatings | 50 |
| Rust preventative coatings | 250 |
| Shellacs | |
| Clear | 730 |
| Opaque | 550 |
| Specialty primers, sealers and undercoaters | 100 |
| Stains | 250 |
| Stone consolidants | 450 |
| Swimming pool coatings | 340 |
| Traffic marking coatings | 100 |
| Tub and tile refinish coatings | 420 |
| Waterproofing membranes | 250 |
| Wood coatings | 275 |
| Wood preservatives | 350 |
| Zinc-rich primers | 340 |

1. Grams of VOC per liter of coating, including water and including exempt compounds.
2. The specified limits remain in effect unless revised limits are listed in subsequent columns in the table.
3. Values in this table are derived from those specified by the California Air Resources Board, Architectural Coatings Suggested Control Measure, February 1, 2008. More information is available from the Air Resources Board.

| TABLE 5.504.4.1 ADHESIVE VOC LIMIT ^{1,2} (Less Water and Less Exempt Compounds in Grams per Liter) | |
|--|------------------|
| ARCHITECTURAL APPLICATIONS | VOC LIMIT |
| Indoor carpet adhesives | 50 |
| Carpet pad adhesives | 50 |
| Outdoor carpet adhesives | 150 |
| Wood flooring adhesive | 100 |
| Rubber floor adhesives | 60 |
| Subfloor adhesives | 50 |
| Ceramic tile adhesives | 65 |
| VCT and asphalt tile adhesives | 50 |
| Drywall and panel adhesives | 50 |
| Cove base adhesives | 50 |
| Multipurpose construction adhesives | 70 |
| Structural glazing adhesives | 100 |
| Single-ply roof membrane adhesives | 250 |
| Other adhesives not specifically listed | 50 |
| SPECIALTY APPLICATIONS | |
| PVC welding | 510 |
| CPVC welding | 490 |
| ABS welding | 325 |
| Plastic cement welding | 250 |
| Adhesive primer for plastic | 550 |
| Contact adhesive | 80 |
| Special purpose contact adhesive | 250 |
| Structural wood member adhesive | 140 |
| Top and trim adhesive | 250 |
| SUBSTRATE SPECIFIC APPLICATIONS | |
| Metal to metal | 30 |
| Plastic foams | 50 |
| Porous material (except wood) | 50 |
| Wood | 30 |
| Fiberglass | 80 |

1. If an adhesive is used to bond dissimilar substrates together, the adhesive with highest VOC content shall be allowed.
2. For additional information regarding methods to measure the VOC content specified in this table, see South Coast Air Quality Management District Rule 1168

| TABLE 5.504.4.2 SEALANT VOC LIMIT (Less Water and Less Exempt Compounds in Grams per Liter) | |
|--|------------------|
| SEALANTS | VOC LIMIT |
| Architectural | 250 |
| Marine deck | 760 |
| Nonmembrane roof | 300 |
| Roadway | 250 |
| Single-ply roof membrane | 450 |
| Other | 420 |
| SEALANT PRIMERS | |
| Architectural | |
| Nonporous | 250 |
| Porous | 775 |
| Modified bituminous | 500 |
| Marine deck | 760 |
| Other | 750 |

| TABLE 5.504.4.5 FORMALDEHYDE LIMITS¹ (Maximum formaldehyde Emissions in Parts per Million) | |
|--|--------------|
| PRODUCT | LIMIT |
| Hardwood plywood veneer core | 0.05 |
| Hardwood plywood composite core | 0.05 |
| Particleboard | 0.09 |
| Medium density fiberboard | 0.11 |
| Thin medium density fiberboard ² | 0.13 |

1. Values in this table are derived from those specified by the California Air Resources Board, Air Toxics Control Measure for Composite Wood as tested in accordance with ASTM E 1333-96(2002). For additional information, see *California Code of Regulations*, Title 17, Sections 93120 through 93120.12
2. Thin medium density fiberboard has a maximum thickness of 8 millimeters